



PIPELINE PARALLEL TO
HV O/H POWER TRANSMISSION LINE



PLAN VIEW

TABLE 1 (NOTE 2)	
SYSTEM VOLTAGE (KV)	MIN. DISTANCE (M)
6.6/11/33	10.00
132/400	25M FOR 150MM DIA 50M FOR 180 - 450 MM DIA 100M FOR >450 MM DIA

PIPELINE CROSSING TO
HV O/H POWER TRANSMISSION LINE



SECTIONAL VIEW

TABLE 2: DEWA RECOMMENDATIONS (NOTE 2, 3 & 4)	
SYSTEM VOLTAGE (KV)	MIN. HEIGHT (M)
6.6/11	8.50
33	9.00
132	9.75
400	13.50

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE NOTED.
2. THE MINIMUM CLEARANCES PROVIDED IN THE DRAWINGS ARE AS PER DEWA REQUIREMENTS. HOWEVER, APPROVED DISTANCES SHALL BE CONFIRMED AFTER INTERFERENCE STUDY ONLY, AS PER NOTE 7.
3. WHERE THE PIPELINE IS ABOVE GRADE, THE MINIMUM HEIGHT REQUIREMENTS SHALL BE MEASURED FROM THE TOP OF BERM.
4. GROUND CLEARANCE SHALL BE CHECKED DURING MAXIMUM TEMPERATURE IN STILL AIR.
5. DETAILED CP CALCULATIONS SHALL BE CARRIED FOR EACH CROSSING FOR ADOPTING MITIGATION MEASURES REQUIRED FOR PROTECTING THE PIPELINE AND TO PREVENT INTERFERENCE WITH PIPELINE CP SYSTEM. CALCULATIONS AND PROPOSED MITIGATIONS SHALL BE APPROVED BY THE COMPANY.
6. HIGH VOLTAGE TERMINAL BOX (CP MONITORING TEST POST) SHALL BE PROVIDED AT EACH CROSSING.
7. AN INTERFERENCE STUDY OF THE OVERHEAD LINE CABLES ON EXISTING PIPELINE(S) MUST BE CONDUCTED BY THE INITIATING PARTY TO DETERMINE THE POSSIBLE IMPACT ON THE EXISTING HYDROCARBON PIPELINES. THE INTERFERENCE STUDY SHALL BE CARRIED OUT FOR BOTH PARALLEL AND

CROSSING INSTALLATIONS USING A DUSUP APPROVED SPECIALIST CONTRACTOR. APPROVED MITIGATION MEASURE SHALL BE IMPLEMENTED BY INITIATING PARTY.

8. THE CONTRACTOR SHALL PREPARE SEPARATE JOB SPECIFIC SHOP DRAWING USING THIS STANDARD DETAILS FOR DUSUP APPROVAL.

INFORMATION CLASSIFICATION: OPEN

						 Dubai Supply Authority	STANDARD DRAWING MINIMUM SEPARATION FOR OVERHEAD LINES (PARALLEL AND CROSSING)									
1	03.02.2025															
0	21.01.2022															
Rev.	Date	Revision Description		Drawn	Checked	Approved	CAD File Name	Size	Scale	Area Code	Doc Code	Serial No.	Sheet of	Sheets	Rev. No.	
							900-08-059-001-R1 MINIMUM SEPARATION OHL.DWG	A3	NTS	9 0 0	0 8	0 5 9	0 0 1	0 0 1	1	